

SERVICE LINES AND METERS

METERS REQUIRED

All water service branches shall be metered, except such branches that are connected with sprinkler systems for fire protection and have no outlets other than the sprinkler heads.

The supply of water through each separate water branch shall be recorded by one meter only, provided that more than one meter will be permitted on a branch to separate commercial consumption from domestic consumption where the use is all under one roof.

APPLICATION

Application for a service line shall be made to the department by the property owner through a licensed master plumber acting as his authorized agent.

SIZING

The size of the service line shall be determined in accordance with the design criteria contained in Indian Hill Water Works specifications and standards. Service lines greater than two (2) inches in size must be specifically approved by the Water Works Superintendent.

LOCATION

The desired location of the service lines, as approved by the Water Works Superintendent, shall be staked in the field by the owner or his agent. Alternately, the desired location of the service line may be specified by a measured distance and a direction from the nearest fire hydrant that is located on the main to be tapped. Failure to set this stake or specify said distance and direction shall be sufficient cause for withholding branch installation.

INSTALLATION

The Indian Hill Water Works Department shall be responsible for the installation of the service line from the main up to and including the service (curb) valve at the property line at the property owner's expense.

The property owner shall be responsible for all work and for all costs incurred in the construction of the service line from the service valve to the meter pit and setting and to any connections within the property. All work shall be done by a licensed master plumber.



VILLAGE OF INDIAN HILL
DEPARTMENT OF WATER WORKS

APPROVED J. D.
DATE November 2011

REGULATIONS OF THE
DEPARTMENT
OF WATER WORKS

DRAWING NO.

WW-105