

In cases of water heaters without thermostatic gas control, a suitable relief valve shall be placed between the outlet side of the meter and the water heater to prevent damage to the meter by hot water or steam.

TESTING

If a meter is tested at the request of the owner, the owner shall pay a charge of \$50.00 provided the meter conforms to industry standards of meter performance, or if the meter does not conform to industry standards to the advantage of the customer (registering too low).

If the meter does not conform to industry standards to the advantage of the Indian Hill Water Works (registering too high), the property owner shall not pay charges for the meter testing.

If it becomes necessary for the Indian Hill Water Works to remove a meter for a period of time for testing and/or repairs, a temporary replacement meter shall be installed, or a by-pass shall be installed and the charge for water used during the absence of the meter shall be based on an estimated amount computed from the average consumption during which the meter is in proper working order.

DISCONTINUANCE OF SERVICE

When the use of a service branch is no longer needed whereby the existing service is either inadequate or improperly located, or whereby the records of Indian Hill Water Works show a discontinuance of service for a period of more than one year, the property owner shall make application for the withdrawal of same. On branches three (3) inches and larger, the actual cost of withdrawal shall be billed to the applicant.

The Water Works Superintendent may cause water to be discontinued to any building or premises or to any portion thereof in which is found an interconnection between the water supply or water distribution pipes and any drain, waste, soil pipe, well, or non-potable water supply.



VILLAGE OF INDIAN HILL
DEPARTMENT OF WATER WORKS

APPROVED *J. Q.*
DATE November 2011

REGULATIONS OF THE
DEPARTMENT
OF WATER WORKS

DRAWING NO.

WW-107