



METER SETTING – 1 1/2" AND 2" METERS

- ① 27" METER SETTING ASSEMBLY WITH BYPASS, FLANGED INLET BALL VALVE, DUAL CHECK ANGLE VALVE OUTLET FORD VBHH76-18B-44-66 OR VBHH76-18B-44-77.
- ② COMPRESSION COUPLING, FORD C84-77 OR C84-66.
- ③ 36" DIA. x 36" LONG MOLDED PVC METER PIT.
- ④ FORD NO. 30 MONITOR COVER WITH INNER LID. EXTRA HEAVY TOP LID REQUIRED IF SUBJECT TO VEHICULAR TRAFFIC (MC-30-T).



VILLAGE OF INDIAN HILL
DEPARTMENT OF WATER WORKS

APPROVED *J.P.*
DATE November 2011

STANDARD METERS AND
SETTINGS - 2 INCH
METERS AND UNDER

DRAWING NO.

WW-134