



SECTIONAL ELEVATION

PIPING LEGEND

WATER METER AS SPECIFIED BY WATER WORKS SUPERINTENDENT.

- ① AWWA C509 RESILIENT SEATED GATE VALVE, NON-RISING STEM.
- ② REDUCING TEE.
- ③ TEE, BRANCH = RUN.
- ④ TEST ASSEMBLY - SEE DETAIL.
- ⑥ SPOOL PIECES, AS REQUIRED.
- ⑦ 90° ELL.
- ⑧ GATE VALVE:
4: NPS, O S & y AWWA C500
2" NPS, bRONZE BODIED WITH RISING STEM.
- ⑨ DRESSER COUPLING.
- ⑩ METER AND VALVE SUPPORT.
- ⑪ SPOOL PIECES FOR TUBINE METERS
a) 8 TO 10 'd' LONG
b) 3 TO 5 'd' LONG
(d = NOMINAL PIPE SIZE, INCHES)
- ⑫ DISMANTLING JOINT COUPLING
(ROMAC INDUSTRIES, INC. STYLE DJ 405
OR APPROVED EQUAL)



VILLAGE OF INDIAN HILL
DEPARTMENT OF WATER WORKS

APPROVED *[Signature]*
DATE February 2013

**STANDARD PIPING
DETAILS**
3 IN. & LARGER METERS

DRAWING NO.

WW-137