



SECTIONAL ELEVATION

PIPING LEGEND

- ① DOUBLE DETECTOR CHECK VALVE, UL LISTED
- ② GATE VALVE, OUTSIDE SCREW AND YOKE, UL-FM LISTED
- ③ 1" METER
- ④ 1" CHECK VALVE
- ⑤ 1" BALL VALVE WITH LOCKING HANDLE
- ⑥ 1" BRONZE NIPPLES, ELLS, AND FITTINGS AS REQUIRED
- ⑦ DISMANTLING JOINT COUPLING
(ROMAC INDUSTRIES, INC. STYLE DJ 405
OR APPROVED EQUAL)



VILLAGE OF INDIAN HILL
DEPARTMENT OF WATER WORKS

APPROVED *J. L.*
DATE February 2013

**STANDARD DOUBLE
DETECTOR CHECK
ASSEMBLY**

DRAWING NO.

WW-144